



SCM FRIGO S.p.A.
Strada Zona Industriale, 10
35020 Vigorovea
di S. Angelo di Piove di Sacco (PD) - ITALY
+39 049 9705000
+39 049 9704947
e-mail: info@scmfrigo.com

Customer: xxxxxxxx
Model: UMT T xxxxx BTDX (v.2.110)
Serial Number: 0Jxxxx
Manufacturing year: 2019
CE Directives: 2006/42/CE, 2014/30/EU, 2014/35/EU
European Normatives:: EN 61439-2, EN 60204-1, EN378-2, EN 14276, EN 13480.



And also accoding to PED 2014/68/EU.

- Conformity evaluating procedure according module H/H1.
N° H1 2017 VE PP 97-1.
- Conformity evaluation notified body: **RINA Services S.p.A..**
N° 0474
- PED Category: I
- Unit pressure equipments and respective evaluating procedures are:

<u>Description:</u>	<u>Code:</u>	<u>Brand:</u>	<u>Q.ty:</u>	<u>Module:</u>	<u>Serial no.:</u>	<u>Serial no.:</u>	<u>Serial no.:</u>	<u>Serial no.:</u>
HP pressure switch	4554107	DANFOSS	1	B+D	-			
HP safety valve	4812058	HENRY	1	B+D	-			
Liquid receiver	2632062	KLIMAL	1	A	-	-		
HP pressure switch	4554117	EMERSON	1	B+D	-			

Other components, not CE marked, are according to Art. 4 par. 3 directive 2014/68/EU.

EU DECLARATION OF CONFORMITY

The signers of the present document, declare, under their exclusive responsibility, that the unit is in conformity with the a.m.Directives and Normatives.

Person authorised to compile the relevant technical documentation (Annex II A) is: Mirko Bernabei.

Vigorovea, 03/06/2019

Il legale rappresentante

Nicola Pignatelli