

# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-CA-2234211-0  
**Report Reference** MH7648-20220831  
**Date** 9-Sep-2022

**Issued to:** DANFOSS A/S  
Nordborgvej 81 Nordborg 6430  
Denmark

**This is to certify that representative samples of** YIOZ7 - Valves, Electrically Operated Certified for Canada  
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.


**Standard(s) for Safety:** CSA C22.2 No. 139-2019, 5th Ed., Issued 1 Dec 2019

**Additional Information:** See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Classified as Business



Bruce Mahrenholz, Director North American Certification Program

UL LLC


Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-CA-2234211-0  
**Report Reference** MH7648-20220831  
**Date** 9-Sep-2022

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

<b>Model</b>	<b>Category Description</b>
EVT, followed by 1.2, 2.0 or 3.0 , followed by NC, followed by 068F0600, -01, -11, -20, -21 or -22, with coil assembly part nos. 018F4180 or -81.	General-purpose valve



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

Classified as Business



# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-US-2235228-0  
**Report Reference** MH7648-20220831  
**Date** 9-Sep-2022

**Issued to:** DANFOSS A/S  
Nordborgvej 81 Nordborg 6430  
Denmark

**This is to certify that representative samples of** YIOZ - Valves, Electrically Operated  
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.


**Standard(s) for Safety:** UL 429, 7th Ed., Issue Date: 2013-11-06, Revision Date: 2021-03-19

**Additional Information:** See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

Classified as Business



# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-US-2235228-0  
**Report Reference** MH7648-20220831  
**Date** 9-Sep-2022

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

<b>Model</b>	<b>Category Description</b>
EVT, followed by 1.2, 2.0 or 3.0 , followed by NC, followed by 068F0600, -01, -11, -20, -21 or -22, with coil assembly part nos. 018F4180 or -81.	General-purpose valve



Classified as Business



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>